

Hello Gerry

Thank you for the clarification.

We have updated the drawings to reflect your comments. Please find attached our revised drawing submission:

1. Building height has been revised to 6.6m (centerline – measured from eave to peak). Data, section and elevations have been updated.
2. Parking stall has been shifted down on the site to allow for 7m *clear* across the width of the stall (please note the orientation of the driveway access is required to be perpendicular to the road, per engineering requirements, so we have left it as is).

Yours Truly,



Roya Darvish Architect AIBC
Associate

LOW HAMMOND ROWE ARCHITECTS INC
300 - 1590 Cedar Hill X Road
Victoria BC V8P 2P5

250 472 8013 x212

www.lhra.ca