

MA
+
HG

**932 Balmoral & 1701 Quadra St
Architectural Rezoning & Development Permit TRG Response
Revisions List**

June 02, 2026

<u>Sheet No.</u>	<u>Revisions</u>
A0.01	Development Data Summary: Commercial floor area updated due to widened parkade aisle and adjusted shear wall location. Parking data updated accordingly (no changes to parking required).
A2.10	Shear wall locations updated. Parking stalls revised at Commercial Parking due to relocated shear walls. Reduced aisle width at southeast corner of the parkade has been increased to 22'. Parking stalls at the end of this reduced aisle have increased clearances to sidewalls.
A2.11	North wall of commercial unit revised due to aligned shear wall at P1. Extent of glazing at Amenity updated due to shear wall location.
A3.03	Extent of glazing at Amenity updated due to shear wall location.
FSR	Commercial floor area updated due to widened parkade aisle and adjusted shear wall location. Total FSR unchanged.