



**932 Balmoral & 1701 Quadra St
Architectural Rezoning & Development Permit TRG Response
Revisions List**

AUGUST 17, 2026

<u>Sheet No.</u>	<u>Revisions</u>
A0.01	Development Data Summary: required parking calculation for assembly use has been updated to 1 space per 30m ² .
A1.11	Mechanical equipment and screening added to the roofs of the new North and East additions.
A2.07	Mechanical equipment and screening added to the roofs of the new North and East additions.
A2.10	Parking drive aisle width revised to 23'-0" (7.01m) throughout.
A2.11	Shear wall between CRU and Garbage Room moved based on adjusted parking drive aisle below.
A3.00	Mechanical equipment and screening added to the roof of the New East addition.
A3.01	Mechanical equipment and screening added to the roof of the New North addition.
A3.02	Mechanical equipment and screening added to the roofs of the new North and East additions.
A3.05	Mechanical equipment and screening added to the roofs of the new North and East additions.
A3.10	Mechanical equipment and screening added to the roof of the new East additions.
A3.11	Mechanical equipment and screening added to the roof of the new North additions.
A3.12	Mechanical equipment and screening added to the roofs of the new North and East additions.
A3.13	Mechanical equipment and screening added to the roofs of the new North and East additions.
FSR	Commercial floor area updated due to widened parkade aisle and adjusted shear wall location. Total FSR unchanged.