

# HAPA COLLABORATIVE

934 Balmoral

Landscape Rezoning & Development Permit Resubmission

Revisions List

August 17, 2026

| <u>Sheet No.</u> | <u>Revisions</u>                                                                                                                                                                                                                                                                                                |
|------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| L1.01            | <ul style="list-style-type: none"><li>• Extents of rain garden modified slightly to accommodate required storage, adjacent planters tweaked to accommodate sufficient pathway widths</li></ul>                                                                                                                  |
| L1.04            | <ul style="list-style-type: none"><li>• Calculations modified to focus on storage volume requirement only, rain garden modified to increase storage capacity, catchment areas highlighted for Marino cells and rain garden</li></ul>                                                                            |
| L4.02            | <ul style="list-style-type: none"><li>• All trees meet 2m offset from building projections. Tree in PA6 and one tree in PA 7 no longer counted as replacement trees due to inability to meet offset. Cash will be provided in lieu. MV species code has been properly reflected in planting schedule.</li></ul> |
| L4.41            | <ul style="list-style-type: none"><li>• Rain garden on slab detail revised to meet updated storage requirement.</li></ul>                                                                                                                                                                                       |

